

COOL THERM

COOL THERM

(Private label for Super Therm@ in Japan)

PROJECTS IN JAPAN

~ 2014.12



DAIKO SHOKAI CO., LTD.

3-11-23 Nagai-higashi, Sumiyoshiku, Osaka, Japan

Room Temperature Data after 18 years

KOKUYO Co., Ltd.

Application Date: July, 1994 Area: 6,000sq.m. (Batten Seam Metal Roof)
Measurement Date: 30 July, 2012 (13:00 Ambient temp: 33.5°C)

18 years has passed since COOL THERM was applied in 1994, the surface stained badly. (Top Coat has never been applied since then.)

The room temperature was still reduced and maintained by 3.5°C from 39°C (39°C-35.5°C) when the ambient temp was measured the same (30 July-33.5°C).



After 10 years (1994)



After 18 years (2012)

	Outside Temperature	Room Temperature
BEFORE (1994)	<u>33.5°C</u>	39°C
AFTER (1994)	32.5°C	32°C
After 10 years(2004)	34.3°C	33.5°C
After 18 years(2012)	<u>33.5°C</u>	35.5°C


Room Temperature Data after 16 years

TOSHIBA Logistics Corp

Application Date: August, 1996 Area: 16,500sq.m. (Metal Roof)
Measurement Date: 24 July, 2012 (13:00 Ambient temp: 35.6°C)

It still maintains the same room temperature and effect after 16 years.

Only top coat has been applied after 12 years, and room temperature has dropped in addition. Surface temperature was measured 37°C~38°C.



<Surface Temperature>




	Outside Temperature	Room Temperature
BEFORE (1994)	35.5°C	39.2°C
AFTER (1994)	35.5°C	32.9°C
After 10 years (2006)	35°C	33°C
Top Coat was applied in 2008		
After 16 years (2012)	35.6°C	31°C

LIXIL CORPORATION Chita Plant

(Aichi)


Metal Roof 9,000m² April 2011



When the outside temp. was almost the same, the sccond flour' s room temperature was reduced by almost 10 C (43.8-34.1C).

Room Temperature
Max. **10.3 C** Difference


	9 July	10 July	16 July	17 July
Weather	☀	☁/☀	☀	☁/☀
Ambient	34.5	33.7	33.8	33.5
Uncoated	44.2	44.4	43.8	42.6
Super Therm	35.4	34.5	33.5	32.9
Difference	-8.8	-9.9	-10.3	-9.7



Company M Sanyo Plant

(Hyogo, Food plant)

Metal Roof 3,000m² August 2011




Where the room has low traffic, the room temperature was reduced by more than 10C which makes the customer satisfied with.

Cut 40% of Air-conditioning electricity consumption

JFE Chemical Fukuyama Plant (Hiroshima)


Metal Roof 660m² August 2009




Measured in a building which has ceiling board and 100mm insulation.

Insulation board hold heat in nature, it becomes big air-conditioning load.

SUPER THERM can come to a settlement of the problem.



Variation of consumed power in a day by Chudenko (before and after of SUPER THERM application)



Energy Saving

Consumed Power Before 180~200KWh/day
After 100~110KWh/day



Consumed power reduced by **38.8%**

Comparison with domestic paint

Company S (Hyogo)


Slate roof 3,600m² May 2009



Coat SUPER THERM and competition paint in a same building roof. 3 months later, in August measure the room temperature.


Room temp. difference with domestic paint

MAX. 5.4°C




August	8/1	8/2	8/3	8/4	8/5	8/6	8/7	8/8	8/9	8/10	8/11	8/12	8/13	8/14	8/15	8/16	8/17	8/18	8/19	8/20
Weather	☀/☁	☀/☁	☀	☀	☀/☁	☁	☁/☀	☀/☁	☀/☁	☀	☁	☁	☁	☁/☀	☀/☁	☀/☁	☀	☀	☀/☁	☀/☁
Ambient temp.	30.6	31.3	34.3	34.4	32.7	32.8	33.9	35.9	28.3	29.0	33.0	35.0	33.4	32.2	30.8	33.1	35.1	33.8	34.7	33.8
Uncoated	35.7	36.6	42.5	43.7	42.2	39.6	41.9	44.9	31.7	29.0	36.2	42.6	39.5	38.3	35.2	38.5	42.7	42.5	43.1	43.1
Another company	35.8	36.3	41.2	40.3	39.6	38.3	39.5	43.0	31.7	32.4	35.5	39.1	36.5	37.1	33.2	38.9	41.1	40.1	40.0	38.5
SUPER THERM	31.6	32.0	35.8	35.2	35.2	33.5	34.9	37.7	29.0	29.7	33.8	36.3	34.5	34.4	30.9	35.6	36.8	35.6	35.1	34.5
Difference	-4.2	-4.3	-5.4	-5.1	-4.4	-4.8	-4.6	-5.3	-2.7	-2.7	-1.7	-2.8	-2.0	-2.7	-2.3	-3.3	-4.3	-4.5	-4.9	-4.0

Metal roof 12,454m² July 2013



Compare before and after the application,
 it was 8.9°C difference between room temp. - ambient temp. ,
 it became 0.2°C only after the application.
 So **the room temp. was reduced by 8.7°C**(8.9°C-0.2°C).



Before the application							
June	6/3	6/4	6/7	6/8	6/13	6/14	6/16
Weather	☁/☀	☀	☀/☁	☀	☀/☁	☁	☀
Ambient temp.	23.0	24.6	25.0	26.0	28.7	28.0	27.2
Room Temp.	30.9	34.4	34.9	34.0	37.2	37.4	34.3
Difference	7.9	9.8	9.9	8	8.5	9.4	7.1

SUPER THERM application							
July - August	7/28	8/3	8/4	8/11	8/12	8/13	8/14
Weather	☀	☀	☀	☀	☀	☀	☀
Ambient temp.	32.1	30.3	31.0	35.8	33.9	33.1	32.0
Room Temp.	31.5	30.6	31.1	34.8	35.0	32.6	31.9
Difference	-0.6	0.3	0.1	-1	1.1	-0.5	-0.1

■YKK AP Inc. Hyogo Plant (Hyogo)

Metal roof 1,350 m² October 2011
 1,750 m² June 2012
 4,700 m² May 2013
 570 m² July 2014



■Room temperature measured result (Height 10m building 2F 1.8m above the floor)

	BFORE June 10 2012	AFTER June 22 2012
Ambient	24.5°C	24.8°C
Room temp.	35.1°C	26.4°C

Room temp.
8.7°C reduced

YKK AP Inc. Kyusyu
 Kumamoto 45,500 m²
 1996~2013




YKK AP Inc. Okayama
 Okayama 2,000 m²
 June 2013



■ PanaHome Corporation Head office (Shiga)

Metal roof 22,700m² December 2010




Before the application, the room temperature exceeded above 5-6°C of ambient temp., but after SUPER THERM application it reduced by the same amount the ambient.


After the application, room temp. of first and second floor are kept the same and we feel its effect.

Room Temp.
Reduced by MAX. 7.3°C

2010 Summer



2011 Summer




—●— Ambient —●— 2F Room temp.

August	8/2	8/3	8/4	8/5	8/6	8/7
Weather	☀	☁/☀	☁/☀	☁/☀	☀	☀/☁
Ambient temp.	33.0	33.0	35.0	35.0	35.0	34.0
2F room temp.	38	38	40	41	40	40
Difference	5.0	5.0	5.0	6.0	5.0	6.0




	8/10	8/11	8/12	8/13	8/14	8/15
Weather	☀	☁/☔	☀	☀/☁	☀	☔/☁
Ambient temp.	35.2	32.9	35.1	35.3	35.9	34.0
2F room temp.	35.8	32.3	33.7	36.3	35.3	33.3
Difference	0.6	-0.6	-1.4	1.0	-0.6	-0.7

Metal roof 20,000m² February - April 2006



Room temp.
MAX. **8.7°C** reduced


The room temp. was reduced by 6.8°C, MAX. 8.7°C after SUPERTHERM application, comparing uncoated with a same structure of the plant.



April	4/3	4/4	4/5	4/6	4/7	4/8	4/9	4/10	4/11	4/12	4/13	4/14	4/15	4/16	4/17	Average
Ambient temp.	35.4	35.2	35.3	36.0	35.9	34.2	34.9	35.6	34.8	36.4	35.7	35.3	35.3	34.4	33.5	35.2
①Uncoated	38.9	39.8	42.3	42.8	42.1	38.1	42.1	39.6	40.1	44.0	39.8	42.3	41.9	40.0	40.5	41.0
②SUPER THERM	33.8	34.0	34.8	35.5	35.3	32.9	34.1	33.5	34.1	35.3	34.3	34.8	34.5	33.1	33.5	34.2
Difference (①-②)	5.1	5.8	7.5	7.3	6.8	5.2	8.0	6.1	6.0	8.7	5.5	7.5	7.4	6.9	7.0	6.8

ProLogis, NYSE: PLD Warehouse for Beijing Olympics (Beijing, China)

Galvalume metal roof 14,300m² April 2008



In middle of May
Room Temp. **6°C** Difference

Date: May 14 2008
Observer: Mr. OH, ProLogis
Ambient temp. : 22°C
Results:

Roof surface temp.	Uncoated	61.2°C	31.7°C Difference
	SUPER THERM	29.5°C	

Room temp. (1.6m above the floor)	Uncoated	22.6°C	6.0°C Difference
	SUPER THERM	16.6°C	

We expect more cooling effect in summer time.


Uncoated



SUPER THERM



Metal roof 10,000m² July 2011




Comparing Room temp. of Uncoated in 2010 and SUPER THERM application in 2011.




Room temp.
11.7°C Reduced

Holidays of no air-conditioning




July/August	7/25	8/1	8/29	Application	8/15	8/16	8/29
Weather	☀	☁	☀/☁		☀	☀	☀
Ambient temp.	32.7	33.0	31.4		30.7	32.3	31.5
Room temp.	40.7	39.8	38.8		33.5	33.8	27.1
Difference	8.0	6.8	7.4		2.8	1.5	-4.4

Metal roof 32,000m² September 2006



Mesured after 1 year of SUPER THERM Application



August 11 2008																								
Time	1時	2時	3時	4時	5時	6時	7時	8時	9時	10時	11時	12時	13時	14時	15時	16時	17時	18時	19時	20時	21時	22時	23時	24時
Ambient	30.2	30.0	29.6	29.7	29.1	28.6	28.3	29.6	30.5	31.4	32.9	34.1	34.2	35.4	35.8	35.5	35.2	34.6	33.5	32.4	31.8	30.7	30.3	30.1
Uncoated	30.5	30.3	30.2	30.0	29.9	29.8	29.6	29.7	30.0	30.6	31.0	31.8	32.4	33.0	33.7	33.9	34.1	33.8	33.4	32.8	32.3	31.9	31.6	31.2
SUPER THERM	29.0	28.8	28.7	28.6	28.5	28.3	28.2	28.2	28.7	29.2	29.7	30.4	30.8	31.3	31.8	32.2	32.3	32.3	32.1	31.5	31.0	30.6	30.3	30.0
Difference	-1.5	-1.5	-1.5	-1.4	-1.4	-1.5	-1.4	-1.5	-1.3	-1.4	-1.3	-1.4	-1.6	-1.7	-1.9	-1.7	-1.8	-1.5	-1.3	-1.3	-1.3	-1.3	-1.3	-1.2

August 12 2008																
Time	1時	2時	3時	4時	5時	6時	7時	8時	9時	10時	11時	12時	13時	14時	15時	16時
Ambient	29.9	30.0	29.3	29.2	28.7	28.8	28.8	29.6	30.7	32.2	33.0	34.4	35.4	35.9	36.0	34.9
Uncoated	30.9	30.6	30.5	30.4	30.3	30.2	30.0	30.0	30.5	31.2	31.9	32.4	33.1	33.5	33.8	33.8
SUPER THERM	29.7	29.5	29.3	29.1	29.0	28.8	28.8	28.8	29.2	30.0	30.6	31.2	31.8	32.1	32.3	32.0
Difference	-1.2	-1.1	-1.2	-1.3	-1.3	-1.4	-1.2	-1.2	-1.3	-1.2	-1.3	-1.2	-1.3	-1.4	-1.5	-1.8

High roof (14m)
and opening doors
it always maintains
1-2°C low room temp.

Heiwado use Gas air-cooling typed air-conditioning. After SUPER THERM Application, they cut the usage of has for air-conditioning by **4 1 %~ 4 9 %** Especially in September summer time (August 16~September 15) the usage of gas was cut by **5 0 %** comparing with the year before. It is a big energy saving effect.

**Gas usage
Cut 49%**



8,000 m² August–September 2013

◆ August

BEFORE		SUPER THERM
2012	2013	2014
No data	6 1 5 5 m ³	3 5 0 7 m ³

Cut 4 3 %

◆ September


BEFORE		SUPER THERM
2012	2013	2014
5 6 8 6 m ³	4 9 3 8 m ³	2 9 1 5 m ³

Cut 4 1 %

Cut 4 9 %

The application period may influence in 2013, however it can be pure a comparison with 2012 and 2014.

Slate Roof & Metal roof 4,000m² May 2011



Around roof temp.
Reduced **12.9°C**

Roof temp.
Reduced **5.3°C**

■ Temperature of 0.5m below roof①

August	Ambient	Room temp.	Difference	Result
2009 Uncoated	29.6°C	44.3°C	14.7°C	12.9°C Reduced
2011 SUPER THERM	30.8°C	32.6°C	1.8°C	
September	Ambient	Room temp.	Difference	Result
2009 Uncoated	27.0°C	39.4°C	12.4°C	11.3°C Reduced
2011 SUPER THERM	27.4°C	28.5°C	1.1°C	

■ Temperature of 0.5m below roof②

August	Ambient	Room temp.	Difference	Result
2009 Uncoated	29.6°C	42.4°C	12.8°C	12.1°C Reduced
2011 SUPER THERM	30.8°C	31.5°C	0.7°C	
September	Ambient	Room temp.	Difference	Result
2009 Uncoated	27.0°C	38.1°C	11.1°C	10.5°C Reduced
2011 SUPER THERM	27.4°C	28.0°C	0.6°C	


■ Room Temperature

August	Ambient	Room temp.	Difference	Result
2009 Uncoated	30.0°C	34.2°C	4.2°C	5.3°C Reduced
2011 SUPER THERM	31.1°C	30.0°C	-1.1°C	
September	Ambient	Room temp.	Difference	Result
2009 Uncoated	27.0°C	30.3°C	3.3°C	4.3°C Reduced
2011 SUPER THERM	27.4°C	26.4°C	-1.0°C	

※Average temp. through 1 month including rainy days

Reconstruction support of The 2011 the Pacific coast of Tohok Earthquake


Temporary house (Miyagi) 18,000m² August 2011



SUPER THERM was provided for volunteer to all the temporary houses in Iwanuma, Miyagi as a government-financed aid project for the summer heat in temporary houses.

Hope the life will be comfortable for next years.

Attic temperature
Reduced MAX. **12.7°C**



September	9/15	9/16	9/17	9/18	9/19	9/20	9/21	9/22	9/23	9/24	9/25	9/26	9/27	9/28	9/29
Weather	☔/☁	☁	☁	☀	☔	☔	☔	☔	☔/☔	☀/☔	☀	☁/☀	☁	☁/☀	☀
Ambient temp.	37.1	40.1	40.6	41.8	25.1	18.0	17.5	24.3	34.7	36.7	35.7	29.6	37.7	37.8	37.9
Uncoated	36.2	43.8	37.9	41.4	24	17.8	17.7	29.1	35.9	34.2	33.2	31.4	37.4	34.6	36.6
SUPER THERM	28.5	31.1	30.2	31.8	27.5	23.0	22.3	24.0	23.6	25.9	24.5	22.8	24.9	24.2	26.0
Difference	-7.7	-12.7	-7.7	-9.6	3.5	5.2	4.6	-5.1	-12.3	-8.3	-8.7	-8.6	-12.5	-10.4	-10.6

Panasonic Electric Works Co., Ltd.

Mie 6,000m²
July 2014



Panasonic Appliances Co., Ltd.

Shiga 8,600m²
March 2012




Shiga 4,500m²
August 2013



Panahome Corporation

Shiga 1,900m²
July 2012



Panasonic Logistics Co., Ltd.

Osaka 2,000m²
March 2009




Center office 1,200m²
March 2009



Irisohyama Inc. Saitama

Saitama 4,300m²
August 2012



Irisohyama Inc. Kadota

Miyagi 10,200m²
August 2011



**Coca-Cola Central
Japan Co., Ltd.**

Tokaikita Aichi 640m²
May 2013



Akindo Sushiro Co., Ltd.

Hyogo 640m²
July 2013



Starbucks Coffee Japan

Toyama 250m²
June 2014



Sunny Mart Co., Ltd.

Kochi 4,000m²
May 2014




Life Corporation

Kyoto 1,550m²
August 2012



Life Corporation

Osaka 1,500m²
July 2011



SATAKE Kyuhoji

Osaka 2,130m²
August 2012



Super Mino

Osaka 2,000m²
March 2014



James Toyokawa

Aichi 1,670m²
March 2012



Bears – mall

Osaka 7,700m²
2007–2009



**JTEKT Corporation
Osaka**

4,000㎡
August 2006

5,500㎡
December 2013



**Toyota Hokkaido Parts
Distributor Co., Ltd.**


Logistic center 8,500㎡
May 2012

**Toyota Mie Parts
Distributor Co., Ltd. Ise**

Mie 800㎡
February 2013

**Toyota Mie Parts
Distributor Co., Ltd. Yokkaichi**

Mie 2,000㎡
February 2013



Isuzu Motors Limited Kyusyu

Fukuoka 5,600㎡
May 2012

Daihatsu Motor Co., Ltd.

Shiga 850㎡
December 2013

**Hitachi Construction Machinery
Tierra Co., Ltd.**

Shiga Roof 3,700㎡ Wall480㎡
March 2014



AGC Wakasa Chemical Co., Ltd.

Fukui 1,800m²
August 2012



Sysmex Corporation Ono plant

Hyogo 3,160m²
January 2013



**Tanabe Seiyaku Yoshiki
Factory Co., Ltd.**

Gifu 5,900m²
May 2012



Fukuei Steel Corporation

Osaka 10,230m²
September 2012



Seiko Resin Corporation

Gunma 4,760m²
September 2012



Hayashi Paper Corporation

Shizuoka 1,400m²
February 2013



Tada Plastic Co., Ltd.

Osaka 3,100m²
September 2011



Oji Nepia Co., Ltd.

Fukushima 6,000m²
June 2012



Fujikura Co., Ltd. Sakura

Chiba 12,000m²
November 2012



**Sumitomo Electric Printed
Circuits Co., Ltd.**

Shiga 2,280m²
June 2014




**Mitsubishi Nichiyu Forklift
Co., Ltd.**

Center Office Kyoto 4,500m²
May 2014



LIXIL Corporation

Shiga 2,600m²
March 2014




Hayama Denki Co., Ltd.

Mie 3,100m²
April 2013




Shoda Shoyu Co., Ltd.

Gunma 2,200m²
June 2012




TAIYO Center plant

Osaka 8,700m²
August 2012



Tokaiishi Corporation Okazaki

Aichi Slate 400m²
August 2012



Senju Metal Industry Co., Ltd.

Tochigi 2,500m²
October 2012



Fuji Seihan Printing Corporation

Hyogo 3,800m²
June 2013



Bando Chemical Industries, Ltd. Kakogawa

Hyogo 1,700m²
March 2012



■ After 12 years


SuperTher	Uncoate	Effect
37.3°C	54.8°C	17.5°C

■ Seper Therm March 2012

SuperTher	Uncoate	Effect
34.8°C	56.8°C	22°C

■ Another coating August 2011

SuperTher	Uncoate	Effect
40.3°C	53.6°C	13.3°C



Kyoto Tool Co., Ltd.

Kyoto 5,800m²
July 1996, recoated in 2013



It still maintains the coating film on the roof after **17 years** of SUPER THERM Application.

【Surface temperature】
Uncoated 65°C
Super Therm 39.3°C

Toray Corporation

Shiga 2,050m²
June 2013

Kainan Frozen Warehouse

Wakayama Slate 2,500m²
June 2013

Shirai Food Corporation

Iwate 1,600m²
April 2012



■ Roof Surface Temperature

May 30 2014 Sunny
Ambient temperature 29.4°C

Uncoated	53.3°C
SUPER THERM	31.5°C
Difference	21.8°C